



Leak Detection Fact Sheet #1

For Some USTs, Inventory Control “Expires” December 22, 1998

***For some older underground storage tanks (USTs),
December 22, 1998 marks the end of the use of inventory
control and tank tightness testing to meet federal leak
detection requirements.***

***If your UST matches the description below,
make sure you are ready to start new monthly monitoring
leak detection by December 23, 1998.***

***“Installed with corrosion
protection” means tank
is made of coated and
cathodically protected
steel (such as sti-P₃®),
fiberglass, or steel that
is clad or jacketed with
a noncorrodible
material.***

This deadline affects your leak detection practices if your tank was either installed with corrosion protection or had corrosion protection added *before* December 22, 1988. These USTs could **temporarily** meet federal leak detection requirements by using a combined method that includes both inventory control and tank tightness testing. Similarly, many tanks of 551 to 2,000 gallons capacity could use a combined method that includes manual tank gauging and periodic tank tightness testing.

Federal regulations limit the use of combined methods with these USTs until December 1998. **For these USTs only, “temporary use” of the combined method ends December 22, 1998.**

***“Corrosion protection
added” to tank means
adding external
cathodic protection,
internal lining, or both.***

Starting December 23, 1998, these USTs must have monthly monitoring leak detection using such methods as interstitial monitoring, an automatic tank gauging system, vapor monitoring, groundwater monitoring, or statistical inventory reconciliation.

See the table on the reverse side for minimum federal requirements.

For USTs Installed Or Upgraded Before December 22, 1988

Questions		Answers	
Does tank have corrosion protection (and, if so, when)?	Does pipng have corrosion protection <i>and</i> does UST have spill and overfill protection?	You can use inventory control plus tightness testing (or, <i>if applicable</i> , manual tank gauging plus tightness testing)	
		Annually	Every 5 years
No	No	Through 12/22/98	No
No	Yes	Through 12/22/98	No
Yes (any time)	No	Through 12/22/98	No
Yes (on or before 12/22/88)	Yes	-->	Through 12/22/98
Yes (after 12/22/88)	Yes	-->	Until 10 years <i>after tank has corrosion protection</i>

Please note that you may need to begin monthly monitoring leak detection earlier than shown above, if the tank's upgrade was based on an alternative integrity assessment method (such as corrosion modeling or video inspection). Check with your implementing agency for requirements in your area.

To find out how long USTs may be able to use the combined method of leak detection, check with your implementing agency for guidance. For information on contacting your implementing agency or to ask questions about UST requirements, call EPA's toll-free hotline at 1-800-424-9346 or visit our Web site at <http://www.epa.gov/OUST/>.